



Alabama Department of Transportation



October 2010 Updates

Americans with Disabilities Act (ADA) Transition Plan 2008

A handwritten signature in black ink, appearing to read "D. J. McInnes".

D. J. McInnes
Transportation Director

TRANSITION PLAN

The Self-Evaluation indicated that all ALDOT facilities are in need of some modifications in some areas. After surveying the Central Office Complex, Division Offices, District Offices, Rest Areas, and Welcome Centers, it was found that there is at least one accessible route into each building. Additional work is needed to minimize and manage the remaining obstacles in areas such as restrooms, telephones, drinking fountains, and offices. An evaluation of exterior paths among ALDOT buildings, including such features as curb ramps, sidewalks, handrails, and contrasting striping on stairs, revealed some areas in need of modification.

The facilities survey was divided into five categories. They were 1) parking, 2) curb, 3) access, 4) entrance, and 5) interior.

The Parking Section included the number of parking spaces, paved or unpaved, handicap parking spaces, location of handicap spaces, size of handicap parking spaces, handicap signage, and van-accessible parking spaces.

The Curb Section included presence of curb cut, location of curb cut, width of curb cut, slope and feather of curb cut.

The Access Section included distance from parking area to building; presence of steps, ramp, or both; number of steps; slope from curb to building; and width of sidewalk.

The Entrance Section included proper landing area at door, clear door width, direction of door swing, type door opener, presence of a vestibule, distance to interior door, clear width of interior door, direction of swing of interior door, type of door opener, and type door lock.

The Interior Section included existence of handicap water fountains, unobstructed corridor width, presence of handicap restrooms, blocked exit doors, elevators for multi-story buildings, and evacuation plans.

ALDOT Engineers provided standard cost figures for the various modifications that would be required to comply with the ADA. A general contractor estimate was developed to calculate the cost of executing the modifications. The total estimated amount was \$1,742,173.95. Some modifications to the central office complex have already been completed, or are currently in process, and they

were/are covered under another budget request. An ADA policy and complaint procedure has been distributed and posted at all ALDOT facilities.

When the modifications are completed, ALDOT facilities will comply with the Uniform Federal Accessibility Standards (UFAS). Each Division and District representative and/or their designees will be responsible for ADA Compliance in their respective locations. Advisory committees will be formed in each location and regular meetings, to include public involvement, will be scheduled to address needs and/or modifications.

All new construction will be designed to meet ADA standards. Construction of new facilities will meet or exceed the Americans with Disabilities Act Accessibility Guidelines for Buildings and Facilities (ADAAG). Each Division will be responsible for ensuring that all new construction meets this standard. Overall monitoring will be performed by the ADA Coordinator and Assistant ADA Coordinator. The monitoring of compliance will be conducted on a quarterly basis; however, random site reviews will also be conducted.

Short-term Goals

Short-term goals consisting of (1) striping and signage of parking areas, (2) signage and grab bars within restrooms, (3) providing TTY phones, (4) retreading stairways, and (5) replacing door handles are already in process. Projected completion date is December 2008.

Long-term Goals

Long-term goals include the installation of (1) automatic doors, (2) curb ramps and cuts, (3) accessible drinking fountains, (4) accessible lavatories, (5) make available an accessible website for people with disabilities, and (6) provide a process to monitor sub-recipients.

The projected completion date is December 2009, and is contingent upon budgetary allowances.

Attached are the cost forms for the Central Office, Divisions, and Districts. Also provided is the Statewide Transportation Improvement Plan (STIP).

Currently there are two (2) Division offices, 2nd and 4th that are under design, and various District offices are being designed for renovation. ALDOT's long range goals for each facility should be met during the designing phase. New Rest Area facilities are being designed for the 2nd, 4th and 5th Division. ADA requirements will be incorporated in designing all ALDOT facilities using the ADAAG.

**AMERICANS WITH DISABILITIES ACT TITLE II
TRANSITION PLAN
FOR THE
STATE OF ALABAMA, DEPARTMENT OF TRANSPORTATION**

PUBLIC NOTICE

The State of Alabama, Department of Transportation (DOT) is requesting public comment on its Self Evaluation for the Americans with Disabilities Act (ADA).

Interested person may review copies of the Self Evaluation in its entirety at the DOT Central Office 1409 Coliseum Boulevard, Room N-101, Montgomery, AL; and at ALDOT's District Offices.

Comments should be submitted no later August 15, 2008.
Please send comments and recommendations to:

Alabama Department of Transportation
1409 Coliseum Boulevard, N-101
Montgomery, Alabama 36110
Attn: Mr. Byron Browning
Phone: (334) 242-6942 -- Fax: (334) 263-7586 -- TTY (800) 877-8339

Auxiliary aids and services are available upon request; please contact the ALDOT ADA Coordinator.

EXECUTIVE SUMMARY

The Alabama Department of Transportation's (ALDOT) Transition Plan has been developed to fulfill the requirements of the Americans with Disabilities Act of 1990 (public law 101-336) under the implementing regulations for Title II, 28 CFR Part 35 §35.150 (d).

Methodology

The DOT's Transition Plan reflects the results of a comprehensive review and survey of the buildings, facilities, programs, and practices that are under the jurisdiction of the Department; who, through its functions, provide these programs and services to the public. The surveying and review identified both programmatic and architectural barriers to persons with disabilities interested in accessing the DOT's programs and services.

CENTRAL OFFICE

ALABAMA DEPARTMENT OF TRANSPORTATION
AMERICANS WITH DISABILITIES ACT
SELF-EVALUATION COST FORM

DATE: October 2010

DIVISION: CENTRAL OFFICE DISTRICT/LOCATION: _____

PROBLEM IDENTIFIED	CORRECTIVE ACTION TO BE TAKEN	PROJECTED DATE OF COMPLETION	ESTIMATED COST LABOR/MATERIALS
1. South entrance	1. Install automatic door opener	1. October 2007	Building in the process of being remodeled.
2. Restrooms	2. Install rear grab bars	2. October 2007	
3. Accessibility sign on ALDOT sign	3. Have the sign shop remake the sign	3. October 2007	
4. Accessibility sign on entrance doors	4. Make raised brail signs for entrance doors	4. October 2007	
5. Designate van space	5. designate van space	5. October 2007	Completed
6. Sign for van access	6. Provide a sign for van accessibility parking	6. October 2007	Completed
Comments			

Comments

ALABAMA DEPARTMENT OF TRANSPORTATION
AMERICANS WITH DISABILITIES ACT
SELF-EVALUATION COST FORM

DATE: October 2010

DISTRICT/LOCATION: Gunter Annex

DIVISION: _____

PROBLEM IDENTIFIED	CORRECTIVE ACTION TO BE TAKEN	PROJECTED DATE OF COMPLETION	ESTIMATED COST LABOR/MATERIALS
1. Sign needed for accessibility Aldot sign	1. Make new ALDOT with accessibility sign	1. October 2007	
2. Sign needed for van accessibility	2. Make a new accessibility sign	2. October 2007	
3. Space needed for van accessibility	3. Make a space for van accessibility	3. October 2007	
4. Automatic door opener needed	4. Install an automatic door opener	4. October 2007	
Comments			

ALABAMA DEPARTMENT OF TRANSPORTATION
AMERICANS WITH DISABILITIES ACT
SELF-EVALUATION COST FORM

DATE: October 2010

DISTRICT/LOCATION: _____

DIVISION: MULTIMODAL

PROBLEM IDENTIFIED	CORRECTIVE ACTION TO BE TAKEN	PROJECTED DATE OF COMPLETION	ESTIMATED COST LABOR/MATERIALS
1. Signs for inaccessible doors	1. Have signs made	1. October 2007	
2. Accessibility sign on the street	2. Have a new sign made with accessibility sign	2. October 2007	
3. Designated parking needs to be blue	3. Paint designated parking blue	3. October 2007	
4. Space for van accessibility	4. Provide one (1) space for van accessibility	4. October 2007	
5. Need ADA drinking fountain	5. Provide one (1) ADA drinking fountain	5. October 2007	
Comments			

FIRST DIVISION

ALABAMA DEPARTMENT OF TRANSPORTATION
Americans with Disabilities Act
Self-Evaluation Cost Form

Date: October 2010

Division:

FIRST

District/Location:

GUNTERSVILLE

Problem Identified	Corrective Action To be taken	Projected Date of Completion	Estimated Cost Labor/Materials
<p>RESTROOMS</p> <ol style="list-style-type: none"> Male/female lavatory cabinets need modification to allow for wheelchair access Ensure that at least one male urinal is in compliance Need rear grab bars in the water closets 	<p>RESTROOMS</p> <ol style="list-style-type: none"> Install new lavatory cabinets that allow for wheelchair access Make modifications to ensure that one male urinal is in compliance. Install new grab bars in the water closets 	<p>RESTROOMS</p> <ol style="list-style-type: none"> September 2008 September 2008 September 2008 	
<p>BUILDING ENTRANCE</p> <ol style="list-style-type: none"> Installation of an automatic door system (push pad) Possible installation of a two-way speaker system Parking spaces need to be painted in blue, allow for van access and at least one or two spaces for vehicles 	<p>BUILDING ENTRANCE</p> <ol style="list-style-type: none"> Move handicap parking to front parking lot near existing automatic door system Install two-way speaker system Stripe handicap accessible spaces in blue and allow for one van access and two vehicle spaces 	<p>BUILDING ENTRANCE</p> <ol style="list-style-type: none"> See Comments Below September 2008 See Comments Below 	<p>BUILDING ENTRANCE</p> <p style="border: 1px solid red; padding: 2px;">Completed</p> <p style="border: 1px solid red; padding: 2px;">Completed</p> <p style="border: 1px solid red; padding: 2px;">Completed</p>
<p>SIGNAGE</p> <ol style="list-style-type: none"> Placement of an accessibility sign on the ALDOT street/highway post Placement of an accessibility sign at the designated building entrance Placement of tactile signs to denote various door openings and hazardous areas 	<p>SIGNAGE</p> <ol style="list-style-type: none"> Install handicap accessibility sign on ALDOT highway sign Install accessibility sign at the building entrance Place any signs as needed to denote door openings or hazardous areas 	<p>SIGNAGE</p> <ol style="list-style-type: none"> September 2008 September 2008 September 2008 	

Comments:

We have a project under construction to expand, resurface and stripe our parking areas. Handicap parking and accessibility has been included in the plans for this project.

ALABAMA DEPARTMENT OF TRANSPORTATION

Americans with Disabilities Act

Self-Evaluation Cost Form

Date: October 2010

Division: FIRST District/Location: DISTRICT 1 / DECATUR

Problem Identified	Corrective Action To be taken	Projected Date of Completion	Estimated Cost Labor/Materials
<p><u>RESTROOMS</u></p> <ol style="list-style-type: none"> Male/female lavatory cabinets need modification to allow for wheelchair access Need rear grab bars in the water closets 	<p><u>RESTROOMS</u></p> <ol style="list-style-type: none"> Install new lavatory cabinets that allow for wheelchair access Install new grab bars in the water closets 	<p><u>RESTROOMS</u></p> <ol style="list-style-type: none"> September 2008 September 2008 	
<p><u>SIGNAGE</u></p> <ol style="list-style-type: none"> Placement of an accessibility sign on the ALDOT street/highway post. Designated parking spaces need to be painted blue Provide one space for van accessibility Placement of an accessibility sign at the designated building entrance Placement of accessibility signs on restroom doors 	<p><u>SIGNAGE</u></p> <ol style="list-style-type: none"> Install handicap accessibility sign on ALDOT highway sign Stripe handicap spaces in blue Provide van accessible space Place handicap accessibility sign at the designated building entrance Place handicap accessibility signs on restroom doors 	<p><u>SIGNAGE</u></p> <ol style="list-style-type: none"> September 2008 September 2008 September 2008 September 2008 September 2008 	

Comments:

ALABAMA DEPARTMENT OF TRANSPORTATION

Americans with Disabilities Act

Self-Evaluation Cost Form

Date: October 2010

Division: FIRST District/Location: DISTRICT 2 / HUNTSVILLE

Problem Identified	Corrective Action To be taken	Projected Date of Completion	Estimated Cost Labor / Materials
<p><u>SIGNAGE</u></p> <ol style="list-style-type: none"> 1. Placement of an accessibility sign on the ALDOT street/highway post 2. Placement of an accessibility sign at the building entrance 3. Placement of accessibility signs on restroom doors 	<p><u>SIGNAGE</u></p> <ol style="list-style-type: none"> 1. Install handicap accessibility sign on ALDOT highway sign 2. Place handicap accessibility sign at the building entrance 3. Place handicap accessibility signs on restroom doors 	<p><u>SIGNAGE</u></p> <ol style="list-style-type: none"> 1. September 2008 2. September 2008 3. September 2008 	
<p><u>RESTROOMS</u></p> <ol style="list-style-type: none"> 1. Need rear grab bars behind toilet 	<p><u>RESTROOMS</u></p> <ol style="list-style-type: none"> 1. Place new grab bars in water closets 	<p><u>RESTROOMS</u></p> <ol style="list-style-type: none"> 1. September 2008 	
<p><u>BUILDING ENTRANCE</u></p> <ol style="list-style-type: none"> 1. Inaccessible door knob needs to be replaced with lever or loop handle 	<p><u>BUILDING ENTRANCE</u></p> <ol style="list-style-type: none"> 1. Replace door knob on the designated entrance for access by disabled individuals with lever or loop handle 	<p><u>BUILDING ENTRANCE</u></p> <ol style="list-style-type: none"> 1. September 2008 	

Comments:

ALABAMA DEPARTMENT OF TRANSPORTATION

Americans with Disabilities Act

Self-Evaluation Cost Form

Date: October 2010

Division: **FIRST** District/Location: **DISTRICT 3 / DUTTON**

Problem Identified	Corrective Action To be taken	Projected Date of Completion	Estimated Cost Labor / Materials
<p><u>SIGNAGE</u></p> <ol style="list-style-type: none"> 1. Placement of an accessibility sign on the ALDOT street/highway post 2. Placement of an accessibility sign at the building entrance 3. Placement of accessibility signs on restroom doors 	<p><u>SIGNAGE</u></p> <ol style="list-style-type: none"> 1. Install handicap accessibility sign on ALDOT highway sign 2. Place handicap accessibility sign at the building entrance 3. Place handicap accessibility signs on restroom doors 	<p><u>SIGNAGE</u></p> <ol style="list-style-type: none"> 1. September 2008 2. September 2008 3. September 2008 	
<p><u>PARKING AREA</u></p> <ol style="list-style-type: none"> 1. Designate a space for van and vehicle accessibility with proper signs 	<p><u>PARKING AREA</u></p> <ol style="list-style-type: none"> 1. Designate a space for van and vehicle accessibility with proper signs 	<p><u>PARKING AREA</u></p> <ol style="list-style-type: none"> 1. September 2008 	
<p><u>BUILDING ENTRANCE</u></p> <ol style="list-style-type: none"> 1. Inaccessible door knob needs to be replaced with lever or loop handle 	<p><u>BUILDING ENTRANCE</u></p> <ol style="list-style-type: none"> 1. Replace door knob on the designated entrance for access by disabled individuals with lever or loop handle 	<p><u>BUILDING ENTRANCE</u></p> <ol style="list-style-type: none"> 1. September 2008 	

Comments:

ALABAMA DEPARTMENT OF TRANSPORTATION

Americans with Disabilities Act

Self-Evaluation Cost Form

Date: October 2010.

Division: FIRST **District/Location:** DISTRICT 4 / JOPPA

Problem Identified	Corrective Action To be taken	Projected Date of Completion	Estimated Cost Labor / Materials
<p><u>RESTROOMS</u></p> <ol style="list-style-type: none"> 1. Modify lavatory cabinets to allow access for wheelchair 2. Installation of rear grab bars in water closets <p><u>PARKING AREA</u></p> <ol style="list-style-type: none"> 1. Paint designated spaces for van/ vehicle access in blue <p><u>BUILDING ENTRANCE</u></p> <ol style="list-style-type: none"> 1. Need accessibility sign on designated entrance door 	<p><u>RESTROOMS</u></p> <ol style="list-style-type: none"> 1. Modify or replace lavatory cabinets to allow for wheelchair access 2. Install new grab bars in water closets <p><u>PARKING AREA</u></p> <ol style="list-style-type: none"> 1. Paint designated spaces for van/ vehicle access in blue <p><u>BUILDING ENTRANCE</u></p> <ol style="list-style-type: none"> 1. Place accessibility sign on designated entrance door 	<p><u>RESTROOMS</u></p> <ol style="list-style-type: none"> 1. September 2008 2. September 2008 <p><u>PARKING AREA</u></p> <ol style="list-style-type: none"> 1. September 2008 <p><u>BUILDING ENTRANCE</u></p> <ol style="list-style-type: none"> 1. September 2008 	<p style="color: red; border: 1px solid red; padding: 2px;">Completed</p>
<p style="color: red; border: 1px solid red; padding: 2px;">2. Restrooms need to be renovated</p>			

Comments:

ALABAMA DEPARTMENT OF TRANSPORTATION
 Americans with Disabilities Act
 Self-Evaluation Cost Form

Date: October 2010

Division: FIRST

District/Location: I-65 REST AREA / CULLMAN

Problem Identified	Corrective Action To be taken	Projected Date of Completion	Estimated Cost Labor / Materials
<p><u>RESTROOMS</u></p> <ol style="list-style-type: none"> Installation of rear grab bars in water closets <p><u>PARKING AREA</u></p> <ol style="list-style-type: none"> Designate parking spaces for van accessibility Create an access lane for wheelchair accessibility Consideration must be directed at creating a specific parking area for RV's and busses that are in close proximity to the facilities on the North bound parking area <p><u>REST AREA GROUNDS</u></p> <ol style="list-style-type: none"> At least two covered picnic table areas must be made accessible for wheelchair individuals. The covered area must be designated with the proper signage 	<p><u>RESTROOMS</u></p> <ol style="list-style-type: none"> Install new grab bars in water closets <p><u>PARKING AREA</u></p> <ol style="list-style-type: none"> Designate parking spaces for van accessibility Create an access lane for wheelchair accessibility Create specific parking area for RV's and busses that are in close proximity to facilities on the North bound parking area <p><u>REST AREA GROUNDS</u></p> <ol style="list-style-type: none"> Make at least two covered picnic table areas accessible for wheelchair individuals. The covered areas will be designated with the proper signage 	<p><u>RESTROOMS</u></p> <ol style="list-style-type: none"> September 2008 <p><u>PARKING AREA</u></p> <ol style="list-style-type: none"> September 2008 September 2008 At time funding for rest area renovation is made available <p><u>REST AREA GROUNDS</u></p> <ol style="list-style-type: none"> September 2008 	

Comments:

ALABAMA DEPARTMENT OF TRANSPORTATION

Americans with Disabilities Act

Self-Evaluation Cost Form

Date: October 2010

Division:

FIRST

District/Location:

I-65 WELCOME CENTER

Problem Identified	Corrective Action To be taken	Projected Date of Completion	Estimated Cost Labor / Materials
<p><u>SIGNAGE</u></p> <ol style="list-style-type: none"> 1. Placement of an accessibility sign on the highway rest area sign 2. Placement of a large accessibility sign on the post denoting car/van/bus parking areas 	<p><u>SIGNAGE</u></p> <ol style="list-style-type: none"> 1. Place accessibility sign on the highway rest area sign 2. Place large accessibility sign on the post denoting car/van/bus parking areas 	<p><u>SIGNAGE</u></p> <ol style="list-style-type: none"> 1. See comments below 2. See comments below 	
<p><u>PARKING AREA</u></p> <ol style="list-style-type: none"> 1. Create two additional accessibility parking spaces and two bus parking spaces in close proximity to the facilities at the southern end of the parking area. 	<p><u>PARKING AREA</u></p> <ol style="list-style-type: none"> 2. Create two additional accessibility parking spaces and two bus parking spaces in close proximity to the facilities at the southern end of the parking area. 	<p><u>PARKING AREA</u></p> <ol style="list-style-type: none"> 1. See comments below 	
<p><u>OTHER CONCERNS</u></p> <ol style="list-style-type: none"> 1. Designate one picnic table area for handicap accessibility and make modifications. 2. Install two handrails (one near the entrance to the restrooms and one at the main entrance) 	<p><u>OTHER CONCERNS</u></p> <ol style="list-style-type: none"> 1. One picnic table area will be designated for handicap accessibility and modifications made. 2. Installation of two handrails (one near the entrance of the restrooms and one at the main entrance) 	<p><u>OTHER CONCERNS</u></p> <ol style="list-style-type: none"> 1. See comments below 2. See comments below 	
<p><u>INTERNAL MODIFICATIONS</u></p> <ol style="list-style-type: none"> 1. Install handicap accessible water fountains 2. Modify lavatory in the male and female restrooms to allow for wheelchair access 	<p><u>INTERNAL MODIFICATIONS</u></p> <ol style="list-style-type: none"> 1. Installation of handicap accessible water fountains 2. Modifications to male and female restroom lavatories for wheelchair access 	<p><u>INTERNAL MODIFICATIONS</u></p> <ol style="list-style-type: none"> 1. See comments below 2. See comments below 	

Comments:

This Welcome Center is scheduled for renovations and will include handicap accessibility in the plans.

SECOND DIVISION

ALABAMA DEPARTMENT OF TRANSPORTATION
 Americans with Disabilities Act
 Self-Evaluation Cost Form

Date: October 2010

Division: 2nd District/Location: Central Division Office

Problem Identified	Corrective Action To be taken	Projected Date of Completion	Estimated Cost Labor/Materials
<ol style="list-style-type: none"> 1. Lack of Handicapped Signage and parking 2. Restroom Accessibility 3. Entrance Accessibility <div style="border: 1px solid red; padding: 2px; margin-top: 5px;">4. Rails on entry ramp not according to standards</div>	<ol style="list-style-type: none"> 1. Install Indoor/Outdoor Signs, Paint Handicapped Parking Spaces 2. Install Grab Bars 3. Install Automatic Front Door <div style="border: 1px solid red; padding: 2px; margin-top: 5px;">4. Add second rail with the correct measurements.</div>	<ol style="list-style-type: none"> 1. December 1, 2007 2. December 1, 2007 3. December 1, 2007 	

Comments:

ALABAMA DEPARTMENT OF TRANSPORTATION

Americans with Disabilities Act

Self-Evaluation Cost Form

Date: October 2010

Division: 2nd District/Location: District 1 Office

Problem Identified	Corrective Action To be taken	Projected Date of Completion	Estimated Cost Labor/Materials
<ol style="list-style-type: none"> 1. Lack of Handicapped Signage and parking 2. Restroom Accessibility 3. Building Accessibility 	<ol style="list-style-type: none"> 1. Install Indoor/Outdoor Signs, Paint Handicapped Parking Spaces 2. Install Grab Bars/Lever Door Knobs 3. Install Lever Door Knobs 	<ol style="list-style-type: none"> 1. December 1, 2007 2. December 1, 2007 3. December 1, 2007 	

Comments:

ALABAMA DEPARTMENT OF TRANSPORTATION
 Americans with Disabilities Act
 Self-Evaluation Cost Form

Date: October 2010

Division: 2nd District/Location: District 2 Office

Problem Identified	Corrective Action To be taken	Projected Date of Completion	Estimated Cost Labor / Materials
1. Lack of Handicapped Signage and parking 2. Restroom Accessibility 3. Building Accessibility	1. Install Indoor/Outdoor Signs, Paint Handicapped Parking Spaces 2. Install Grab Bars/Lever Door Knobs, Lavatory Handles 3. Install Lever Door Knobs	1. December 1, 2007~ 2. December 1, 2007 3. December 1, 2007	

Comments:

Building in the planning stage for replacement.

ALABAMA DEPARTMENT OF TRANSPORTATION

Americans with Disabilities Act

Self-Evaluation Cost Form

Date: October 2010

Division: 2nd District/Location: District 3 Office

Problem Identified	Corrective Action To be taken	Projected Date of Completion	Estimated Cost Labor / Materials
<ol style="list-style-type: none"> 1. Lack of Handicapped Signage and parking 2. Restroom Accessibility 3. Building Accessibility 	<ol style="list-style-type: none"> 1. Pave Parking Area, Place Concrete for Wheel Chair Ramp, Indoor/Outdoor Signs, Paint Handicapped Parking Spaces 2. Install Grab Bars, Replace Soap Dispensers 3. Replace Door Handle With Loop Pull 	<ol style="list-style-type: none"> 1. December 1, 2007 2. December 1, 2007 3. December 1, 2007 	<p>Building replaced in 2010. New facility is fully accessible.</p>

Comments:

THIRD DIVISION

ALABAMA DEPARTMENT OF TRANSPORTATION

Americans with Disabilities Act

Self-Evaluation Cost Form

Date: October 2010 —

Division:
Headquarters, Third
Division

District/Location:
Birmingham, AL

Problem Identified	Corrective Action To be taken	Projected Date of Completion	Estimated Cost Labor/Materials
1. Parking Area	1. Create two vehicle i.e., van accessibility parking spaces. Paint area with blue accessibility sign. Install handrail from parking area to the end of the wheel chair ramp.	1. Pending approval of funding	
2. Signage	2. Install directional sign to restrooms	2.	
3. Restrooms	3. Modify access door and lavatory Cabinets in male/female restroom Install grab bars in both water closets	3.	

RP

ALABAMA DEPARTMENT OF TRANSPORTATION

Americans with Disabilities Act

Self-Evaluation Cost Form

Date: October 2010

Division: Third District/Location: One-Birmingham,AL

Problem Identified	Corrective Action To be taken	Projected Date of Completion	Estimated Cost Labor / Materials
1. Parking Area	1. Create two spaces for van accessibility and vehicle parking. Paint affected area	1. Pending approval of funding “	
2. Restrooms	Purchase and place accessibility sign on building. 2. Install signs on male/female entrance and stall doors.	“ 2. “	

Comments:

RF

ALABAMA DEPARTMENT OF TRANSPORTATION

Americans with Disabilities Act

Self-Evaluation Cost Form

Date: October 2010

Division: Third District/Location: Two-Oneonta, AL

Problem Identified	Corrective Action To be taken	Projected Date of Completion	Estimated Cost Labor / Materials
1. Signage	1. Purchase and place accessibility sign on ALDOT highway sign and on the building.	1. Pending approval of funding	
2. Parking Area	2. Designate parking spaces for van/vehicle accessibility.	2. “	
3. Restrooms	3. Install signs on male/female entrance doors.	3. “	

Comments:

ed

ALABAMA DEPARTMENT OF TRANSPORTATION

Americans with Disabilities Act

Self-Evaluation Cost Form

Date: October 2010

Division: Third **District/Location:** Four-Jasper, AL

Problem Identified	Corrective Action To be taken	Projected Date of Completion	Estimated Cost Labor/Materials
1. Signage 2. Parking Area 3. Signs on entry door	1. Purchase and place accessibility sign on ALDOT highway sign and on building. 2. Designate and paint spaces for van/vehicle accessibility. 3. Add accessible signs on entry doors.	1. Pending approval of funding 2. "	

Comments:

[Handwritten Signature]

ALABAMA DEPARTMENT OF TRANSPORTATION

Americans with Disabilities Act

Self-Evaluation Cost Form

Date: October 2010

Division:

Third

District/Location:

Five-Calera, AL

Problem Identified	Corrective Action To be taken	Projected Date of Completion	Estimated Cost Labor/Materials
1. Signage	1. Purchase and place accessibility sign on ALDOT highway sign and on the building.	1. Pending approval of funding	
2. Parking Area	2. Designate and paint parking spaces for van in blue. Replace door handle to building entrance	2. " "	" "

Comments:

[Handwritten mark]

ALABAMA DEPARTMENT OF TRANSPORTATION

Americans with Disabilities Act

Self-Evaluation Cost Form

Date: October 2010

Division: Three-Rest Area I-59 North District/Location: Two-Oneonta, AL

Problem Identified	Corrective Action To be taken	Projected Date of Completion	Estimated Cost Labor/Materials
1. Restrooms Entry door handles	1. Create and install accessibility signs to male/female stall doors. Replace door handles.	1. Pending approval of funding	
2. Signage	2. Purchase and place accessibility sign on highway rest area sign.	"	
3. Parking Area	3. Replacement of accessibility signs at curb side.	"	
	Create additional vehicle parking spaces.	"	Completed
4. Picnic Area	Paint parking area in blue, designate a parking space in the traffic parking area for RV and Bus parking. Install a curb ramp.	4.	
	4. Designate a covered shelter area for wheelchair accessibility; utilize building in rear of building by placing directional signs; make modifications to allow for wheelchair accessibility.	"	

Comments:

APL

ALABAMA DEPARTMENT OF TRANSPORTATION

Americans with Disabilities Act

Self-Evaluation Cost Form

Date: October 2010

Division: Three-Rest Area I-59
South

District/Location: Two-Oneonta, AL

Problem Identified	Corrective Action To be taken	Projected Date of Completion	Estimated Cost Labor / Materials
1. Signage	1. Purchase and place accessibility sign on highway rest area sign.	1. Pending approval of funding	
2. Parking Area	2. Create additional vehicle parking spaces. Paint parking area in blue. Designate a parking space in the southern trailer parking area (near the curb) for RV/bus parking.	2. " "	Completed
3. Restroom	3. Install male/female accessibility stall signs.	3. " "	Completed
4. Water Cooler	4. Install a new cooler		

Comments:

rd

FOURTH DIVISION

**ALABAMA DEPARTMENT OF TRANSPORTATION
Americans with Disabilities Act
Self-Evaluation Cost Form**

Date: October 2010

Division:

Fourth

District/Location:

**Headquarters' Building-
Alexander City**

Problem Identified	Corrective Action To be taken	Projected Date of Completion	Estimated Cost Labor/ Materials
Signage/ Parking Area	<ol style="list-style-type: none"> 1. Placement of an accessibility sign on ALDOT's highway sign. 2. Designate a parking space for van/ vehicle accessibility, paint parking area and post proper accessibility signs according to specifications 3. Designate accessible parking spaces near the lower level auditorium 	<ol style="list-style-type: none"> 1. 2007 2. 2007 3. 2007 	<p>Building in the process of being replaced-- new structure to be completed 11/2012. Building plan calls for full compliance.</p>
Restrooms Male/ Female (Lower and main floor)	<ol style="list-style-type: none"> 1. Widen stall access doors 2. Install lavatory sinks to proper height 3. Install towel dispensers to proper height 4. Install a lower urinal in male restroom 5. Install uniform accessibility signs on entrance and stall doors 	<ol style="list-style-type: none"> 5. 2007 	
Water Cooler/ Drinking Fountain	<ol style="list-style-type: none"> 1. Replace water fountains on lower and main floors to allow for accessibility by wheelchair. 		
Entrance	<ol style="list-style-type: none"> 1. Add automatic door opener 		

Note: consideration should be extended to the installation of a lift/ elevator mechanism from the lower floor to the main floor. Wheelchair access to the main floor is limited and requires physically lifting the individual up the stairs. Estimated cost: \$25,000

ALABAMA DEPARTMENT OF TRANSPORTATION
Americans with Disabilities Act
Self-Evaluation Cost Form

Date: October 2010

Division:

Fourth

District/Location:

District One-Alexander
City

Problem Identified	Corrective Action To be taken	Projected Date of Completion	Estimated Cost Labor/ Materials
Parking Area	1. Designate a parking space for accessibility van/ vehicle and paint according to specifications.	1. 2007	
Entrance	1. Add automatic door opener		
Restrooms	1. Remove or alter cabinetry to provide space underneath in the ladies room.		

ALABAMA DEPARTMENT OF TRANSPORTATION

Americans with Disabilities Act

Self-Evaluation Cost Form

Date: October 2010

Division:

Fourth

District/Location:

District Two-Anniston

Problem Identified	Corrective Action To be taken	Projected Date of Completion	Estimated Cost Labor/ Materials
Signage/ Parking Area	<ol style="list-style-type: none"> 1. Placement of an accessibility sign on ALDOT's highway sign 2. Designate parking spaces for accessibility van/ vehicle and paint according to specifications (on rear side) 3. Install proper curb ramps 4. Install proper door handle on entrance door. 	<ol style="list-style-type: none"> 1. 2007 2. 2007 	<ol style="list-style-type: none"> 1. \$100 2. \$500 3. \$2,000 4. \$3,000
Restrooms Male/ Female	<ol style="list-style-type: none"> 1. Widen door access to stalls 2. Place proper accessibility signage on entrance and stall doors 3. Install rear and side grab bars 4. Install proper level controlled mechanism on sinks 	<ol style="list-style-type: none"> 2. 2007 	<ol style="list-style-type: none"> 1. \$5,000 2. \$100 3. \$1,000 4. \$1,000
Entrance	<ol style="list-style-type: none"> 1. Replace inaccessible knobs with the lever or loop handle 		<ol style="list-style-type: none"> 1. \$3,000

TOTAL

\$15,700.00

ALABAMA DEPARTMENT OF TRANSPORTATION

Americans with Disabilities Act

Self-Evaluation Cost Form

Date: October 2010

Division:

Fourth

District/Location:

District Three-Auburn

Problem Identified	Corrective Action To be taken	Projected Date of Completion	Estimated Cost Labor/ Materials
Signage/ Parking Area	<ol style="list-style-type: none"> 1. Placement of an accessibility sign on ALDOT's highway sign 2. Designate parking spaces for accessibility van/ vehicle and paint according to specifications 	<ol style="list-style-type: none"> 1. 2007 2. 2007 	
Restrooms Male/ Female	<ol style="list-style-type: none"> 1. Widen door access to stalls 2. Place proper accessibility signage on entrance and stall doors 3. Install rear and side grab bars 4. Reposition the tissue dispenser 5. Install proper height lavatory sink with level controlled mechanisms 6. Place proper and uniform accessibility signage on entrance and stall doors 	<ol style="list-style-type: none"> 2. 2007 4. 2007 	
Entrance	<ol style="list-style-type: none"> 1. Replace inaccessible knobs with the lever or loop handle—Auto door 		

ALABAMA DEPARTMENT OF TRANSPORTATION

Americans with Disabilities Act

Self-Evaluation Cost Form

Date: October 2010

Division:

Fourth

District/Location:

**District Four-Hollis
Crossroads**

Problem Identified	Corrective Action To be taken	Projected Date of Completion	Estimated Cost Labor/ Materials
Signage/ Parking Area	<ol style="list-style-type: none">1. Placement of an accessibility sign on ALDOT's highway sign2. Designate parking spaces for accessibility van/ vehicle and paint according to specifications	<ol style="list-style-type: none">1. 20072. 2007	

Note: Complete restroom renovation is required to render this facility in compliance with ADA. Also, replacement of the water cooler is necessary. Estimated cost is \$30,000

**ALABAMA DEPARTMENT OF TRANSPORTATION
Americans with Disabilities Act
Self-Evaluation Cost Form**

Date: October 2010

Division:

Fourth

District/Location:

District Five-Talladega

Problem Identified	Corrective Action To be taken	Projected Date of Completion	Estimated Cost Labor/ Materials
Signage/ Parking Area	<ol style="list-style-type: none"> 1. Placement of an accessibility sign on ALDOT's highway sign 2. Designate parking spaces for accessibility van/ vehicle and paint according to specifications (on rear side) 3. Install curb and door ramps 	<ol style="list-style-type: none"> 1. 2007 2. 2007 	
Restrooms Male/ Female	<ol style="list-style-type: none"> 1. Widen door access to stalls 2. Install proper level controlled mechanisms on sinks 3. Place proper accessibility signs on entrance and stall doors 	<ol style="list-style-type: none"> 3. 2007 	
Water Cooler/ Drinking Fountain	<ol style="list-style-type: none"> 1. Replace to allow for wheelchair access 		

ALABAMA DEPARTMENT OF TRANSPORTATION

Americans with Disabilities Act

Self-Evaluation Cost Form

Date: October 2010

Division:

Fourth

District/Location:

District 6-Seale

Problem Identified	Corrective Action To be taken	Projected Date of Completion	Estimated Cost Labor/ Materials
Signage/ Parking Area	<ol style="list-style-type: none">1. Placement of an accessibility sign on ALDOT's highway sign.2. Designate parking spaces for accessibility van/vehicle and paint according to specifications3. Install curb and door ramps	<ol style="list-style-type: none">1. 20072. 2007	

ALABAMA DEPARTMENT OF TRANSPORTATION

Americans with Disabilities Act

Self-Evaluation Cost Form

Date: October 2010

Division:

Fourth

District/Location:

**Division Four Rest Area
Welcome Center Georgia/
Alabama I-20**

Problem Identified	Corrective Action To be taken	Projected Date of Completion	Estimated Cost Labor/ Materials
Signage/ Parking Area	<ol style="list-style-type: none"> 1. Placement of an accessibility sign on ALDOT's highway sign. 2. Reposition accessibility parking spaces to close proximity to the facility and paint according to specifications 	1. 2007	
Restrooms Male/ Female	<ol style="list-style-type: none"> 1. Install rear grab bars 2. Lower the tissue dispenser 	2. 2007	
Picnic Area	<ol style="list-style-type: none"> 1. Designate a covered shelter for wheelchair accessibility and modify to specifications 		

ALABAMA DEPARTMENT OF TRANSPORTATION

Americans with Disabilities Act

Self-Evaluation Cost Form

Date: October 2010

Division:

Fourth

District/Location:

**Division Four Rest Area
Welcome Center (Alabama/
Georgia I-85 South)**

Problem Identified	Corrective Action To be taken	Projected Date of Completion	Estimated Cost Labor/ Materials
Signage/ Parking Area	<ol style="list-style-type: none"> 1. Placement of an accessibility sign on ALDOT's highway sign. 2. Repaint the accessibility parking spaces blue and according to specifications 3. Designate a parking space for RV/ Bus in trailer parking area with curb and ramp modifications 4. Install a hand rail system from the parking area to the facility 	<ol style="list-style-type: none"> 1. 2007 2. 2007 	
Restrooms Male/ Female	<ol style="list-style-type: none"> 1. Widen entrance doors to access stalls 2. Install rear grab bars 3. Place proper and uniform accessibility signs on entrance and stall doors 4. Reposition tissue dispenser 	<ol style="list-style-type: none"> 2. 2007 	

Note: Consideration should be directed at exploring the possibility of constructing a "family room/unisex restroom" facility at each rest area.

ALABAMA DEPARTMENT OF TRANSPORTATION
Americans with Disabilities Act
Self-Evaluation Cost Form

Date: October 2010

Division:

Fourth

District/Location:

Division Four Rest Area
(280) South

Problem Identified	Corrective Action To be taken	Projected Date of Completion	Estimated Cost Labor/ Materials
			Rest Area Closed July 2007

FIFTH DIVISION

ALABAMA DEPARTMENT OF TRANSPORTATION

Americans with Disabilities Act

Self-Evaluation Cost Form

Date: October 2010

Division: FIVE **District/Location:** Headquarters' Building

Problem Identified	Corrective Action To be taken	Projected Date of Completion	Estimated Cost Labor / Materials
1. Parking Area	1. Designate parking spaces for van/ vehicle parking and create an additional vehicle parking space	06/15/08	Completed
2. Signage	2. Place accessibility signs on ALDOT highway sign, entrance door to building and on rest room stall doors in male/female facilities	07/31/07	
3. Water Cooler/Drinking Fountain	3. Replace water cooler to allow for accessibility by wheelchair	08/31/07	

Comments:

ALABAMA DEPARTMENT OF TRANSPORTATION

Americans with Disabilities Act

Self-Evaluation Cost Form

Date: October 2010

Division: FIVE District/Location: District One – Fayette

Problem Identified	Corrective Action To be taken	Projected Date of Completion	Estimated Cost Labor / Materials
1. Signage	1. Place accessibility sign on ALDOT highway sign	06/15/08	Building was remodeled in 2010. Building and its facilities are accessible.
2. Parking Area	2. Designate parking spaces for van/ vehicle accessibility and paint area blue Repair uneven paving Change the entrance door handle mechanisms	06/15/08 06/15/08 07/31/07	
3. Restrooms	3. Both restrooms require extensive renovations to be in compliance (see note below – building scheduled for major renovations)		

Comments:

NOTE: This building is scheduled for major renovations in the near future. Completion date: 12/08 Completed

ALABAMA DEPARTMENT OF TRANSPORTATION

Americans with Disabilities Act

Self-Evaluation Cost Form

Date: October 2010

Division: FIVE **District/Location:** District Two – Tuscaloosa

Problem Identified	Corrective Action To be taken	Projected Date of Completion	Estimated Cost Labor / Materials
1. Parking Area	1. Change the entrance door handle mechanisms	07/31/07	
2. Restrooms	2. Extend the doorway to 32 inches to allow for wheelchair access Lower towel dispenser Place accessibility signs on doors	12/15/07 07/15/07 07/31/07	

Comments:

ALABAMA DEPARTMENT OF TRANSPORTATION

Americans with Disabilities Act

Self-Evaluation Cost Form

Date: October 2010

Division: FIVE **District/Location:** District Three - Carrollton

Problem Identified	Corrective Action To be taken	Projected Date of Completion	Estimated Cost Labor/Materials
1. Parking Area	1. Designate parking spaces for van and paint area blue Place accessibility sign on ALDOT highway sign Create an additional vehicle parking space	06/15/08 06/15/08 06/15/08	 Completed
2. Restrooms – Male/Female	2. Place the towel and soap dispensers at proper heights	07/31/07	 Completed

Comments:

ALABAMA DEPARTMENT OF TRANSPORTATION

Americans with Disabilities Act

Self-Evaluation Cost Form

Date: October 2010

Division: FIVE **District/Location:** District Four - Maplesville

Problem Identified	Corrective Action To be taken	Projected Date of Completion	Estimated Cost Labor/Materials
1. Signage	1. Place accessibility sign on ALDOT highway sign	06/15/08	Incomplete
2. Parking Area	2. Designate van/vehicle parking spaces and paint area blue	06/15/08	Building remodeled in 2010. The building and all of its facilities are accessible.
3. Restrooms	3. The facilities are too small for access by a wheelchair (see note below – building scheduled for complete renovations)		

Comments:

Completed in 2010.

NOTE: This building is scheduled for complete renovations.

ALABAMA DEPARTMENT OF TRANSPORTATION

Americans with Disabilities Act

Self-Evaluation Cost Form

Date: October 2010

Division: FIVE **District/Location:** District Five – Greensboro

Problem Identified	Corrective Action To be taken	Projected Date of Completion	Estimated Cost Labor/Materials
<p>1. This building is scheduled for complete renovations.</p> <p>2. We will also be taking ADA issues into consideration.</p>	<p>1.</p>		<div style="border: 1px solid red; padding: 5px;"> Building was renovated in 2010. This facility does comply with the accessibility standards. </div>

Comments:

NOTE: This building is scheduled for complete renovations. Completed in 2010

ALABAMA DEPARTMENT OF TRANSPORTATION

Americans with Disabilities Act

Self-Evaluation Cost Form

Date: October 2010

District Three – I-59/20 West
– Rest Area

Division: FIVE

District/Location:

Problem Identified	Corrective Action To be taken	Projected Date of Completion	Estimated Cost Labor / Materials
1. Parking Area	1. Paint area blue Designate RV / Bus parking area and install curb modification	06/15/08 06/15/08	
2. Restrooms – Male/Female	2. Place accessibility signs on stall doors Install rear grab bars	07/31/07 10/30/07	
3. Picnic Area	3. Designate a covered shelter for wheelchair accessibility	06/15/08	

Comments:

ALABAMA DEPARTMENT OF TRANSPORTATION

Americans with Disabilities Act

Self-Evaluation Cost Form

Date: October 2010

District Three – I-59/20
North/South – Rest Area

Division: FIVE

District/Location:

Problem Identified	Corrective Action To be taken	Projected Date of Completion	Estimated Cost Labor/Materials
1. Parking Area	1. Designate RV/Bus parking area	03/15/08	
2. Signage	Place accessibility sign on the directional highway sign.		
3. Entry Door Handle	Change out entry door handles.		
4. Restrooms	Door handles and lavatory need to be modified to meet accessibility standards.		
5. Picnic Table	Make one picnic table accessible.		

Comments:

NOTE: The facilities are under construction. The larger restroom area will be in compliance. However, the access stall opening in the smaller restroom is not in compliance.

ALABAMA DEPARTMENT OF TRANSPORTATION

Americans with Disabilities Act

Self-Evaluation Cost Form

Date: October 2010

District Three – I-59/20 East
– Rest Area

FIVE

District/Location:

Division:

Problem Identified	Corrective Action To be taken	Projected Date of Completion	Estimated Cost Labor / Materials
1. Parking Area	1. Install additional accessibility signs Create additional vehicle parking spaces Designate RV / Bus parking area	06/15/08	
2. Restrooms – Male/Female	2. Place accessibility signs on stall doors Install rear grab bars in small stalls	06/15/08 07/31/07 10/30/07	
3. Water Cooler	Install an accessible water cooler, according to the regulations.		

Comments:

ALABAMA DEPARTMENT OF TRANSPORTATION

Americans with Disabilities Act

Self-Evaluation Cost Form

Date: October 2010

District Four – I-65 South Rest Area

FIVE

Division:

District/Location:

Problem Identified	Corrective Action To be taken	Projected Date of Completion	Estimated Cost Labor/Materials
1. Signage	1. Place accessibility sign on highway rest area sign Place van accessibility signs in parking area	06/15/08	Still needs sign on the highway.
2. Parking Area	2. Designate a parking area for RV/Bus parking with curb modification (curb modification will be a part of major renovations project) Paint the access parking spaces blue	06/15/08	
3. Picnic Area	3. Designate a covered shelter area for wheelchair accessibility	06/15/08	Facility was renovated in 2010 and it is fully accessible.
4. Restrooms – Male/Female	4. Place accessibility signs with Braille letter notations on entrance and stall doors Install lever controlled mechanisms on faucets Install rear grab bars Reposition the tissue dispenser Reconstruct access stall to allow wheelchair entrance Install urinal at proper height in male restroom	03/15/08 03/15/08 03/15/08 03/15/08	

Comments:

ALABAMA DEPARTMENT OF TRANSPORTATION

Americans with Disabilities Act

Self-Evaluation Cost Form

Date: October 2010

District Four – I-65 North Rest Area

District/Location:

FIVE

Division:

Problem Identified	Corrective Action To be taken	Projected Date of Completion	Estimated Cost Labor / Materials
1. Signage	1. Place accessibility sign on highway rest area sign Place van accessibility sign on proper post	06/15/08	Facility completely renovated in 2010 and it is fully accessible.
2. Parking Area	2. Designate two additional vehicle parking spaces for accessibility Designate the last parking spaces in trailer parking area for RV/Bus parking and install curb modification (curb modification will be a part of major renovations project)	06/15/08 06/15/08	Need accessibility signs on highway.
3. Restrooms – Male/Female	3. Install lever controlled mechanisms on faucets Place accessibility signs with Braille letter notations on entrance and stall doors Install rear grab bars Reposition the tissue dispenser to allow wheelchair access Install urinal at proper height in small male restroom	03/15/08 03/15/08 03/15/08 03/15/08	

Comments:

ALABAMA DEPARTMENT OF TRANSPORTATION

Americans with Disabilities Act

Self-Evaluation Cost Form

Date: October 2010

District Four – Highway 82
– Rest Area

FIVE

District/Location:

Division:

Problem Identified	Corrective Action To be taken	Projected Date of Completion	Estimated Cost Labor/Materials
1. Signage	1. Place accessibility sign on ALDOT highway sign	06/15/08	
2. Parking Area	2. Install proper accessibility signs for designated parking spaces Paint the access parking spaces blue Designate parking space for RV/Bus with proper curb modification	06/15/08 06/15/08 06/15/08	
3. Picnic Area	3. Designate a covered shelter area for wheelchair accessibility	06/15/08	
4. Restrooms – Male/Female	4. Place accessibility signs on entrance and stall doors Install rear grab bars Install lever controlled mechanisms on faucets	03/15/08 03/15/08 03/15/08	

Comments:

NOTE: The restroom facilities are in grave need of immediate refurbishing.

SIXTH DIVISION

ALABAMA DEPARTMENT OF TRANSPORTATION

Americans with Disabilities Act

Self-Evaluation Cost Form

Date: October 2010

Division: Sixth **District/Location:** Main Office

Problem Identified	Corrective Action To be taken	Projected Date of Completion	Estimated Cost Labor/Materials
1. Parking Area	As noted.	As funds become available.	Completed
2. Entrance	Install accessible sign		
3. Restrooms: Male/Female	Accessible signs on restrooms, install grab bars, and replace door handles.		

Comments:

ALABAMA DEPARTMENT OF TRANSPORTATION
 Americans with Disabilities Act
 Self-Evaluation Cost Form

Date: October 2010

Division: Sixth District/Location: Division/ Training Facility

Problem Identified	Corrective Action To be taken	Projected Date of Completion	Estimated Cost Labor / Materials
1. Restrooms: Male/Female	As noted.	As funds become available.	
2. Signage	As noted.	As funds become available.	
3. Entrance	As noted.	As funds become available.	

Comments:

The total building needs to be remodeled to meet accessibility standards.

ALABAMA DEPARTMENT OF TRANSPORTATION
 Americans with Disabilities Act
 Self-Evaluation Cost Form

Date: October 2010

Division: Sixth District/Location: District 1/ Office

Problem Identified	Corrective Action To be taken	Projected Date of Completion	Estimated Cost Labor / Materials
1. Restrooms: Male/Female	Install grab bars.		
2. Signage	Add accessible signs on all doors and on ALDOT's highway Sign.		
3. Parking Area	Designate a space for accessible van parking and paint it blue.		

Comments:

ALABAMA DEPARTMENT OF TRANSPORTATION

Americans with Disabilities Act

Self-Evaluation Cost Form

Date: October 2010

District 2/ Office

District/Location:

Sixth

Division:

Problem Identified	Corrective Action To be taken	Projected Date of Completion	Estimated Cost Labor / Materials
1. Restrooms: Male/Female	Lower towel dispensers.		
2. Signage	Add signs to accessible and inaccessible entrances.		
3. Entrance	Change entrance door handles.		
4. Parking	Reconfigure space for accessible van parking. Add curb ramps.		

Comments:

ALABAMA DEPARTMENT OF TRANSPORTATION

Americans with Disabilities Act
Self-Evaluation Cost Form

Date: October 2010

District 3/ Office

Division: Sixth

District/Location:

Problem Identified	Corrective Action To be taken	Projected Date of Completion	Estimated Cost Labor / Materials
1. Restrooms: Male/Female 2. Parking 3. Entrance 4. Signage 5. Water Cooler	<div style="border: 1px solid red; padding: 2px;">Add an accessibility sign on entrance doors. Add grab bars in restrooms.</div> <div style="border: 1px solid red; padding: 2px;">Add a van accessible par.</div> <div style="border: 1px solid red; padding: 2px;">Install an accessible sign & new door handle.</div> <div style="border: 1px solid red; padding: 2px;">Install an accessibility sign on ALDOT's highway sign.</div> <div style="border: 1px solid red; padding: 2px;">Install an accessible water cooler, according to regulations.</div>		

Comments:

ALABAMA DEPARTMENT OF TRANSPORTATION

Americans with Disabilities Act

Self-Evaluation Cost Form

Date: October 2010

District 4/ Office

Division: Sixth

District/Location:

Problem Identified	Corrective Action To be taken	Projected Date of Completion	Estimated Cost Labor / Materials
1. Signage 2. Restrooms: Male/Female 3. Water Cooler 4. Parking	Add an accessibility sign on ALDOT's highway sign. Remodel Replace Curb cut not to standard		

Comments:

ALABAMA DEPARTMENT OF TRANSPORTATION

Americans with Disabilities Act

Self-Evaluation Cost Form

Date: October 2010

District 5/ Office

District/Location:

Sixth

Division:

Problem Identified	Corrective Action To be taken	Projected Date of Completion	Estimated Cost Labor/Materials
1. Signage	As noted.	As funds become available.	
2. Restrooms: Male/Female	As noted.	As funds become available.	
3. Entrance	As noted.	As funds become available.	

Comments:

Building to be renovated.

ALABAMA DEPARTMENT OF TRANSPORTATION

Americans with Disabilities Act

Self-Evaluation Cost Form

Date: October 2010

District 2/ Rest Area
I-85 Northbound

District/Location:

Sixth

Division:

Problem Identified	Corrective Action To be taken	Projected Date of Completion	Estimated Cost Labor / Materials
1. Restrooms: Male/Female	<div style="border: 1px solid black; padding: 2px;">Add grab bars and replace sink knobs. Remove partitions. Install accessible signs on doors and stalls.</div> <div style="border: 1px solid black; padding: 2px; margin-top: 5px;">As noted.</div>	<div style="border: 1px solid black; padding: 2px;">As funds become available.</div>	<div style="border: 1px solid black; padding: 2px;">Completed</div>
2. Signage			
3. Entrance			
4. Parking	<div style="border: 1px solid black; padding: 2px;">Designate a space for accessible van parking and paint it blue.</div>		
5. Picnic Table	<div style="border: 1px solid black; padding: 2px;">Designate and make one picnic table accessible.</div>		

Comments:

ALABAMA DEPARTMENT OF TRANSPORTATION

Americans with Disabilities Act

Self-Evaluation Cost Form

Date: October 2010

District 2/ Rest Area
I-85 Southbound

Division: Sixth

District/Location:

Problem Identified	Corrective Action To be taken	Projected Date of Completion	Estimated Cost Labor/Materials
1. Signage/Parking	Designate an accessible park and paint it blue. Add an accessible parking sign at the correct height.		
2. Restrooms: Male/Female	Add accessible signs on doors. Lower dispensers and add grab bars.		
3. Entrance	Replace door handles.	AS HANDS BECOME AVAILABLE.	
4. Water Coolers	Install an accessible water cooler, according to regulations.		

Comments:

ALABAMA DEPARTMENT OF TRANSPORTATION
 Americans with Disabilities Act
 Self-Evaluation Cost Form

Date: October 2010

District 4/ Rest Area
 I-65 Southbound

Sixth

District/Location:

Division:

Problem Identified	Corrective Action To be taken	Projected Date of Completion	Estimated Cost Labor/Materials
1. Parking Area 2. Restrooms: Male/Female 3. Water Cooler	<div style="border: 1px solid red; padding: 2px;"> Paint all accessible areas blue and add an area for van accessibility. </div> <div style="border: 1px solid red; padding: 2px;"> Put an accessible sign on doors, and add grab bar in stalls. </div> <div style="border: 1px solid red; padding: 2px;"> Install an accessible water cooler, according to the regulations. </div>		

Comments:

ALABAMA DEPARTMENT OF TRANSPORTATION
 Americans with Disabilities Act
 Self-Evaluation Cost Form

Date: October 2010

District 4/ Rest Area
 I-65 Northbound

Division: Sixth

District/Location:

Problem Identified	Corrective Action To be taken	Projected Date of Completion	Estimated Cost Labor / Materials
1. Restrooms: Male/Female 2. Signage 3. Entrance	As noted. No sign at inaccessible entrances Replace or widen door according to the standards.	As funds become available.	Completed

Comments:

ALABAMA DEPARTMENT OF TRANSPORTATION

Americans with Disabilities Act

Self-Evaluation Cost Form

Date: October 2010

District 5/
Interpretive Center

Sixth

District/Location:

Problem Identified	Corrective Action To be taken	Projected Date of Completion	Estimated Cost Labor/Materials
1. Signage	As noted.	As funds become available.	
2. Restrooms: Male/Female	Add accessible signs on stall doors.		
3. Entrance	Install signs on inaccessible entrances.		
4. Parking	Designate an accessible van and RV/Bus parking area. Paint it blue.		

Comments:

SEVENTH DIVISION

ALABAMA DEPARTMENT OF TRANSPORTATION
Americans with Disabilities Act Self-Assessment Survey
2007 Overview — 7TH DIVISION ESTIMATED COSTS

Date: October 2010

Division Seven-Main Office Building-(Troy):

Problem Identified	Corrective Action to Be Taken	Estimated Costs Labor & Materials	Estimated Costs	Projected Date of Completion
Location Signage/Parking Area	Remarks/Suggestions <ul style="list-style-type: none"> Install accessibility sign on ALDOT highway sign Paint designated accessibility parking spaces for van/vehicle according to specifications 			<ul style="list-style-type: none"> July 31, 2008 July 31, 2008
Restrooms: Male/Female	<ul style="list-style-type: none"> Lower Level-Remodel male restroom for unisex usage including entrances, new stalls, and installation of ADA fixtures including commodes, lavatories, faucets, grab bars, and tile work Main Level-Remodel male restroom for unisex usage including entrances, new stalls, and installation of ADA fixtures including commodes, lavatories, faucets, grab bars, and tile work 			<ul style="list-style-type: none"> April 1, 2009 April 1, 2009
Water Cooler/ Drinking Fountain	<ul style="list-style-type: none"> Replace water fountains on lower and main floors to allow for accessibility (wheelchair & regular fountains) 			<ul style="list-style-type: none"> April 1, 2009

Division Seven-District Five Office-(Troy):
District Five Office @ Troy

Completed and fully accessible. Need accessible signs for all doors and parking spaces.

NOTE: District Office Five in Troy was constructed and built according to the Uniform Accessibility Standards. This District Office Complex was designed by an architect and constructed by an independent contractor to meet the uniform federal accessibility standards as required. No problems identified in this district office.

Other: Parking:

Problem Identified	Corrective Action to Be Taken	Estimated Costs Labor & Materials	Estimated Costs	Projected Date of Completion
Location Signage/Parking Area	Remarks/Suggestions <ul style="list-style-type: none"> Install accessibility sign on ALDOT highway sign & entrance doors Paint designated accessibility parking spaces for van/vehicle according to specifications 			<ul style="list-style-type: none"> April 1, 2009 April 1, 2009

Date: October 2010

Division Seven-District One-Office-(Dothan):

Problem Identified	Corrective Action to Be Taken	Estimated Costs Labor & Materials	Projected Date of Completion
Location	Remarks/Suggestions	Unit/Unit Price	Estimated Costs
Signage/Parking Area	<ul style="list-style-type: none"> Install accessibility sign on ALDOT highway sign Designate an additional parking space for accessibility and paint according to specifications Install accessibility signs on entrance and stall doors Change faucets to lever controlled mechanisms Widen door access to stalls including remodeling of bath room entrance doors, stalls, concrete walls, and tile floors to comply with uniform federal accessibility standards. Includes new commodes, lavatories, and grab bars. 		<ul style="list-style-type: none"> July 31, 2008 July 31, 2008 April 1, 2009 April 1, 2009 April 1, 2009
Water Cooler & Drinking Fountain	<ul style="list-style-type: none"> Remove & install new water fountains to allow for accessibility for wheelchair including relocation of water & plumbing lines 		<ul style="list-style-type: none"> April 1, 2009
Sub-Total		\$15,700.00	

**Division Seven-District One-Rest Area & Welcome Center-Dothan:
U.S. 231, Dothan, Houston County**

Problem Identified	Corrective Action to Be Taken	Estimated Costs Labor & Materials	Projected Date of Completion
Location	Remarks/Suggestions	Unit/Unit Price	Estimated Costs
Signage/Parking Area	<ul style="list-style-type: none"> Place handicap accessibility signs on ALDOT highway signs Designate parking spaces for accessibility van/vehicle and paint according to specifications Add accessible RV/bus parking space Install accessibility signs on entrance and stall doors Install ADA lavatories, faucets, commodes, & relocation of plumbing; Install grab bars in stalls; Modify lavatory sink to proper height and install lever controlled mechanisms Widen door access to stalls including remodeling of bath room entrance doors, stalls, concrete walls, and tile floors to comply with uniform federal accessibility standards. Includes new commodes, lavatories, and grab bars. 		<ul style="list-style-type: none"> July 31, 2008 July 31, 2008 April 1, 2009 April 1, 2009 April 1, 2009 April 1, 2009
Restrooms: Male/Female	<ul style="list-style-type: none"> Remove & install new water fountain to allow for accessibility for wheelchair including relocating plumbing 		<ul style="list-style-type: none"> April 1, 2009
Water Cooler/Drinking Fountain			
Picnic Area	<ul style="list-style-type: none"> Designate a sheltered picnic area for wheel chair accessibility and install pathways. Modify 1 picnic table to ADA standards & install a covered shelter on an existing shelter near the vending machine area to allow for accessibility 		<ul style="list-style-type: none"> April 1, 2009

Date: October 2010

Division Seven-District Two Office-(Enterprise):

Problem Identified Location	Corrective Action to Be Taken Remarks/Suggestions	Estimated Costs Labor & Materials		Projected Date of Completion
		Estimated Costs • Unit/Unit Price	Estimated Costs	
Signage/Parking Area	• Place accessibility sign on ALDOT highway sign			• July 31, 2008
	• Designate parking spaces for accessibility van/vehicle and paint according to specifications			• July 31, 2008
	• Install curb and door entrance ramps			• July 31, 2008
Restrooms: Male/Female	• Install accessibility signs on entrance and stall doors			• April 1, 2009
	• Install ADA lavatories, faucets, commodes, & rear grab bars in stalls			• April 1, 2009
	• Widen entrance doors in bathrooms by removing concrete block walls, installing new walls & doors, and installation of new stalls in both male/female bathrooms			• April 1, 2009
Water Cooler/Drinking Fountain	• Replace water fountain to allow for accessibility for wheelchair including relocation of plumbing			• April 1, 2009

Division Seven-District Three Office-(Andalusia):

NOTE: Completed renovation of the parking area and the restrooms is required to render this facility in compliance with ADA. Also, replacement of water cooler is necessary. Listed below is a breakdown of corrective actions to be taken:

Problem Identified	Corrective Action to Be Taken	Estimated Costs Labor & Materials	Projected Date of Completion
Location	Remarks/Suggestions	• Unit/Unit Price	Estimated Costs
Signage/Parking Area	<ul style="list-style-type: none"> Place accessibility sign on ALDOT highway sign Designate parking spaces for accessibility van/vehicle and paint according to specifications Install curb and door entrance ramps (approximately 80 L.F. x 5" Wide sidewalks for an accessible route and ramp 		<ul style="list-style-type: none"> July 31, 2008 July 31, 2008 July 31, 2008
Restrooms; Male/Female	<ul style="list-style-type: none"> Install accessibility signs on entrance and stall doors Install ADA lavatories, commodes, & relocation of plumbing, and install grab bars in stalls Widen entrance doors in bathrooms by removing concrete block walls, installing new walls & doors, and installation of new stalls in both male/female bathrooms 		<ul style="list-style-type: none"> April 1, 2009 April 1, 2009 April 1, 2009
Water Cooler/Drinking Fountain	<ul style="list-style-type: none"> Replace water fountain to allow for accessibility for wheelchair including relocating plumbing 		<ul style="list-style-type: none"> April 1, 2009

Division Seven-District Three- Rest Area-Florala U.S. 331, Florala, Covington County

Problem Identified	Corrective Action to Be Taken	Estimated Costs Labor & Materials	Projected Date of Completion
Location	Remarks/Suggestions	• Unit/Unit Price	Estimated Costs
Signage/Parking Area	<ul style="list-style-type: none"> Place accessibility sign on ALDOT highway sign Designate parking spaces for accessibility van/vehicle and paint according to specifications 		<ul style="list-style-type: none"> July 31, 2008 July 31, 2008
Restrooms; Male/Female	<ul style="list-style-type: none"> Install accessibility signs on entrance and stall doors Install ADA lavatories, faucets, commodes, & relocation of plumbing; install grab bars in stalls; Modify lavatory sink to proper height and install level controlled mechanisms Widen entrance doors & stalls for both male/female bathrooms 		<ul style="list-style-type: none"> April 1, 2009 April 1, 2009 April 1, 2009
Water Cooler/Drinking Fountain	<ul style="list-style-type: none"> Replace water fountain to allow for accessibility for wheelchair including relocating plumbing 		<ul style="list-style-type: none"> April 1, 2009
Picnic Area	<ul style="list-style-type: none"> Designate a sheltered picnic area for wheel chair accessibility and install pathways. Modify 1 picnic table to ADA standards 		<ul style="list-style-type: none"> April 1, 2009

Date: October 2010

Completed and fully accessible. Need accessible parking signs.

Division Seven-District Four Office-Ozark

NOTE: District Four Office in Ozark is in a temporary facility at this time. A new District Office Complex including District Engineer's office, shop, herbicide building and other buildings are being designed by an architect to render all district facilities to be in compliance with ADA & uniform accessibility standards as required.

**Division Seven-District Four--Rest Area
U.S. 231, Ozark, Dale County**

Problem Identified Location	Corrective Action to Be Taken Remarks/Suggestions	Estimated Costs Labor & Materials		Projected Date of Completion
		Estimated Costs	Unit/Unit Price	
Signage/Parking Area	<ul style="list-style-type: none"> Place accessibility sign on ALDOT highway sign Designate parking spaces for accessibility van/vehicle and paint according to specifications 			<ul style="list-style-type: none"> July 31, 2008 July 31, 2008
Restrooms: Male/Female	<ul style="list-style-type: none"> Install accessibility signs on entrance and stall doors Install ADA lavatories, faucets, commodes, & relocation of plumbing; install grab bars in stalls; modify lavatory sink to proper height and install level controlled mechanisms Widen entrance doors & stalls for both male/female bathrooms 			<ul style="list-style-type: none"> April 1, 2009 April 1, 2009 April 1, 2009
Water Cooler/Drinking Fountain	<ul style="list-style-type: none"> Replace water fountain to allow for accessibility for wheelchair including relocating plumbing 			<ul style="list-style-type: none"> April 1, 2009
Picnic Area	<ul style="list-style-type: none"> Designate a sheltered picnic area for wheel chair accessibility and install pathways. Modify 1 picnic table to ADA standards 			<ul style="list-style-type: none"> April 1, 2009

Date: October 2010

Completed and fully accessible. Accessible sign is needed at the parking doors and complete the sidewalk curb cut.

Division Seven-District Six Office--(Eufaula)

NOTE: District Office Six in Eufaula is scheduled TO BE REPLACED. A new District Office Complex including District Engineer's office and other buildings are being designed by an architect to render the new district facilities to be in compliance with uniform federal accessibility standards as required.

The problems listed below were identified in the ADA Survey in March/2007. We have listed these problems along with the corrective actions to be taken; however, we request this work be omitted, and estimated costs be allocated to the new district facility that is to be constructed.

Problem Identified Location	Corrective Action to Be Taken Remarks/Suggestions	Estimated Costs Labor & Materials		Projected Date of Completion
		Unit/Unit Price	Estimated Costs	
Signage/Parking Area	<ul style="list-style-type: none"> Place accessibility sign on ALDOT highway sign Designate parking spaces for accessibility van/vehicle and paint according to specifications Install curb and door entrances to comply with uniform accessibility standards 			<ul style="list-style-type: none"> •OMIT •OMIT •OMIT
Restrooms: Male/Female	<ul style="list-style-type: none"> Install accessibility signs on entrance and stall doors Install ADA lavatories, faucets, commodes, & rear grab bars in stalls Widen entrance doors in bathrooms by removing concrete block walls, installing new walls & doors, and installation of new stalls in both male/female bathrooms 			<ul style="list-style-type: none"> •OMITT •OMITT •OMITT
Water Cooler/Drinking Fountain	<ul style="list-style-type: none"> Replace water fountain to allow for accessibility for wheelchair including relocation of plumbing 			•OMIT

(*Request to Omit)

Division Seven-District Six-Rest Area-Eufaula
U.S. 431, Eufaula, Barbour County

Problem Identified Location	Corrective Action to Be Taken Remarks/Suggestions	Estimated Costs Labor & Materials		Projected Date of Completion
		Unit/Unit Price	Estimated Costs	
Restrooms: Male/Female	<ul style="list-style-type: none"> Install accessibility signs on entrance and stall doors Install ADA lavatories, faucets, commodes, & relocation of plumbing; install grab bars in stalls; Modify lavatory sink to proper height and install level controlled mechanisms Widen entrance doors & stalls for both male/female bathrooms 			<ul style="list-style-type: none"> •April 1, 2009 •April 1, 2009 •April 1, 2009
Water Cooler/Drinking Fountain	<ul style="list-style-type: none"> Replace water fountain to allow for accessibility for wheelchair including relocating plumbing 			•April 1, 2009
Picnic Area	<ul style="list-style-type: none"> Designate a sheltered picnic area for wheel chair accessibility and install pathways. Modify 1 picnic table to ADA standards 			•April 1, 2009

SUMMARY OF ESTIMATED COSTS ALABAMA DEPARTMENT OF TRANSPORTATION
 Americans with Disabilities Act Self-Assessment Survey
 2007 Overview -- 7TH DIVISION ESTIMATED COSTS SUMMARIZED

BUILDING/LOCATION	ESTIMATED COSTS FOR UNIFORM ACCESSIBILITY STANDARDS
Division Seven-Main Office Building-(Troy)	
Division Seven-District Five Office-----(Troy)	
Division Seven-District One-Office-(Dothan)	
Division Seven-District One-Rest Area & Welcome Center-(Dothan) U.S. 231, Dothan, Houston County	
Division Seven-District Two Office-(Enterprise)	
Division Seven-District Three Office-(Andalusia)	
Division Seven-District Three- Rest Area-(Florala) U.S. 331, Florala, Covington County	
Division Seven-District Four-Office-(Ozark) (Located in Temporary Rental Office)	
Division Seven-District Four--Rest Area-(Ozark) U.S. 231, Ozark, Dale County	
Division Seven-District Six Office--(Eufaula)	
Division Seven-District Six-Rest Area-Eufaula U.S. 431, Eufaula, Barbour County	
TOTAL ESTIMATED COSTS	

EIGHTH DIVISION

ALABAMA DEPARTMENT OF TRANSPORTATION

American with Disabilities Act

Self-Evaluation Cost Form

Date: October 2010

Eighth

Eight-Office
Grove Hill, Alabama

District/Location:

Division:

Problem Identified	Corrective Action To be taken	Projected Date of Completion	Estimated Cost Labor/Materials
1. Parking Area	1. Designate parking spaces for van/vehicle accessibility & paint blue.	1. December 2008	
2. Building Entrance Door	2. Change door handles to allow for easy access. a. Automatic accessibility door button for exterior front door on bridge column. b. Auto-matically control door controlled by front desk receptionist. c. Remove existing concrete curb & sidewalk & replace with accessible ramp.	2. December 2008	
3. Signage	3. Place accessibility signs (with brail) at entrance & restroom & US-84 & on sign & entrance.	3. December 2008	
4. Main Sign	4. Add light to sign with generator Connection.	4. December 2009	
5. Rear Door at Loading Ramp won't swing in	5. Fix to swing in and out.	5. December 2008	

Comments:

ALABAMA DEPARTMENT OF TRANSPORTATION

Americans with Disabilities Act

Self-Evaluation Cost Form

Date: October 2010

District One
Livingston, Alabama

Division: Eighth

District/Location:

Problem Identified	Corrective Action To be taken	Projected Date of Completion	Estimated Cost Labor / Materials
1. Parking Area	1. Designate Parking spaces for van/vehicle accessibility and paint blue.	1. December 2008	
2. Building Entrance Door	2. Change door handles to allow for easy access and install accessibility button opened by receptionist to automatically open doors for the handicapped.	2. December 2008	
3. Signage	3. Entrance-way etc.	3. December 2008	
4. Restrooms	4. Extend District Office building to accommodate ADA compliant restrooms.	4. December 2009	
5. Water Cooler/Drinking Fountain	5. Replacement cooler with accessibility cooler.	5. December 2009	

Comments:

ALABAMA DEPARTMENT OF TRANSPORTATION
 Americans with Disabilities Act
 Self-Evaluation Cost Form

Date: October 2010

Division:

Eighth

District Two
Thomaston, Alabama

District/Location:

Problem Identified	Corrective Action To be taken	Projected Date of Completion	Estimated Cost Labor / Materials
1. Parking Area	1. Designate Parking spaces for van/ vehicle accessibility and paint blue. Install an accessible parking sign.	1. December 2008	
2. Building Entrance Door	2. Change door handles to allow for easy access and install accessibility button operated by desk clerk inside.	2. December 2008	
3. Signage	3. Entrance-way etc.	3. December 2008	
4. Restrooms	4. Extend District Office building to accommodate ADA compliant restrooms.	4. December 2009	
5. Water Cooler/Drinking Fountain	5. Replacement cooler with accessibility cooler.	5. December 2009	
6. Restrooms-Gas House	6. Extend Gas House Building to accommodate ADA compliant restrooms.	6. December 2009	

Comments:

ALABAMA DEPARTMENT OF TRANSPORTATION
 Americans with Disabilities Act
 Self-Evaluation Cost Form

Date: October 2010

District Three
Camden, Alabama

Division: Eighth District/Location: District Three Camden, Alabama

Problem Identified	Corrective Action To be taken	Projected Date of Completion	Estimated Cost Labor / Materials
1. Parking Area	1. Designate Parking spaces for van/vehicle accessibility and paint blue.	1. December 2008	
2. Building Entrance Door	2. Change door handles to allow for easy access and install accessibility button opened by receptionist to automatically open doors for the handicapped.	2. December 2008	
3. Signage	3. Entrance-way etc.	3. December 2008	
4. Restrooms	4. Extend District Office building to accommodate ADA compliant restrooms.	4. December 2009	
5. Omit	5. Omit	5. Omit	
6. Restrooms-Gas House	6. Extend Gas House Building to accommodate ADA compliant restrooms.	6. December 2009	

Comments:

ALABAMA DEPARTMENT OF TRANSPORTATION
 Americans with Disabilities Act
 Self-Evaluation Cost Form

Date: October 2010

District Four
 Grove Hill, Alabama

District/Location:

Eighth

Division:

Problem Identified	Corrective Action To be taken	Projected Date of Completion	Estimated Cost Labor/Materials
1. Parking Area	1. Designate Parking spaces for van/ vehicle accessibility and paint blue.	1. December 2008	
2. Building Entrance Door	2. Change door handles to allow for easy access and install accessibility button opened by receptionist to automatically open doors for the handicapped.	2. December 2008	
3. Signage	3. Entrance-way and parking.	3. December 2008	
4. Restrooms	4. Extend District Office building to accommodate ADA. compliant restrooms	4. December 2009	
5. Omit	5. Omit	5. Omit	
6. Restrooms-Gas House	6. Extend Gas House Building to accommodate ADA compliant restrooms.	6. December 2009	

Comments:

ALABAMA DEPARTMENT OF TRANSPORTATION
 Americans with Disabilities Act
 Self-Evaluation Cost Form

Date: October 2010 —

District One
 Welcome Area I-59/I-20
 Cuba, Alabama

District/Location:

Eighth

Division:

Problem Identified	Corrective Action To be taken	Projected Date of Completion	Estimated Cost Labor/Materials
1. Parking Area	1. In white redo in blue.	1. January 2008	
2. Signage	2. Place accessibility signs on Hwy sign & building.	2. December 2008	
3. Restrooms	3. Place signs, & modify stalls for accessibility. Install grab bars and change facets.	3. December 2009	
4. Rear Entrance Doors Complaints	4. Change door handles to allow for easy access and install accessibility button opened by receptionist to automatically open doors for the handicapped.	4. December 2009	
5. Picnic Area	5. Convert at least one picnic area as accessible.	5. December 2009	

Comments:

NINTH DIVISION

ALABAMA DEPARTMENT OF TRANSPORTATION

Americans with Disabilities Act
Self-Evaluation Cost Form

Date: October 2010

District 1-3

Ninth

Division:

District/Location:

Problem Identified	Corrective Action To be taken	Projected Date of Completion	Estimated Cost Labor/Materials
<ol style="list-style-type: none"> 1. Signage / Parking Area / Modify door entrances. 2. Modify male urinals, towel dispensers, and faucets levers. 3. No sign placed on either restroom door. 4. Water Fountain is not accessible by wheelchair 5. Enlarge restroom stalls to accommodate wheelchairs. 6. Insufficient Sheltered area for handicap access. 	<ol style="list-style-type: none"> 1. Establish and label proper parking areas to accommodate handicap motorist. 1.2 Place proper signs to direct handicap motorist to designated areas. 1.3 Modify entrance doors handles for easy access. 2. Lower urinals, towels dispensers, and install proper faucets to meet ADA standards. 3. Place proper signage on all restroom entrances with Braille inset. 4. Install Water Fountain to meet ADA standards. 5. Enlarge Stalls to accommodate wheelchairs. 6. Construct covered sheltered area for wheelchair access. 	<p>1. - 6. To be Determined</p>	

Comments:

ALABAMA DEPARTMENT OF TRANSPORTATION

Americans with Disabilities Act
Self-Evaluation Cost Form

Date: October 2010

Division: Ninth District/Location: District 1 - / Mobile

Problem Identified	Corrective Action To be taken	Projected Date of Completion	Estimated Cost Labor / Materials
<ol style="list-style-type: none"> 1. Signage / Parking Area / Modify door entrances. 2. Modify male urinals, towel dispensers, and faucets levers. 3. No sign placed on either restroom door. 4. Water Fountain is not accessible by wheelchair 	<ol style="list-style-type: none"> 1. Establish and label proper parking areas to accommodate handicap motorist. 1.2 Place proper signs to direct handicap motorist to designated areas. 1.3 Modify entrance doors handles for easy access. 2. Lower urinals, towels dispensers, and install proper faucets to meet ADA standards. 3. Place proper signage on all restroom entrances with Braille inset. 4. Install Water Fountain to meet ADA standards. 	<p>1. - 4. To be Determined</p>	<div style="border: 1px solid black; padding: 5px; color: red; font-weight: bold;">Completed</div>

Comments:

ALABAMA DEPARTMENT OF TRANSPORTATION

Americans with Disabilities Act

Self-Evaluation Cost Form

Date: October 2010

District 2 / Bay Minette

District/Location:

Ninth

Division:

Problem Identified	Corrective Action To be taken	Projected Date of Completion	Estimated Cost Labor/Materials
<ol style="list-style-type: none"> 1. Signage / Parking Area / Modify door entrances. 2. Modify male urinals; install grab bars, and faucets levers. 3. Water Fountain is not accessible by wheelchair 	<ol style="list-style-type: none"> 1. Establish and label proper parking areas to accommodate handicap motorist. 1.2 Place proper signs to direct handicap motorist to designated areas. 1.3 Modify entrance doors handles for easy access. 1.4 Install ramp to building entrance 2. Lower urinals, and install proper faucets and grab bars to meet ADA standards. 3. Install Water Fountain to meet ADA standards. 	<ol style="list-style-type: none"> 1. - 3. To be Determined 	

Comments:

ALABAMA DEPARTMENT OF TRANSPORTATION

Americans with Disabilities Act

Self-Evaluation Cost Form

Date: October 2010

Division: Ninth

District/Location: District 3 / Evergreen

Problem Identified	Corrective Action To be taken	Projected Date of Completion	Estimated Cost Labor / Materials
1. Signage / Parking Area / Modify door entrances.	1. Establish and label proper parking areas to accommodate handicap motorist. 1.2 Place proper signs to direct handicap motorist to designated areas.	1. - 1.2. To be Determined	(Empty)

Comments:

ALABAMA DEPARTMENT OF TRANSPORTATION
 Americans with Disabilities Act
 Self-Evaluation Cost Form

Date: October 2010

District 1 / Mobile
Rest Area

District/Location:

Ninth

Division:

Problem Identified	Corrective Action To be taken	Projected Date of Completion	Estimated Cost Labor/Materials
1. Signage / Parking Area / Modify door entrances to restrooms. 2. Enlarge restroom stalls to accommodate wheelchairs	1. Establish and label proper parking areas to accommodate handicap motorist. 1.2 Place proper signs to direct handicap motorist to designated areas. 1.3 Place proper signage on all restroom entrances with Braille inset. 2.0 Enlarge stall to accommodate wheelchairs.	1. - 2.0 To be Determined	

Comments:

ALABAMA DEPARTMENT OF TRANSPORTATION

Americans with Disabilities Act

Self-Evaluation Cost Form

Date: October 2010

District 2 / Bay Minette
Rest Area

Division:

Ninth

District/Location:

Problem Identified	Corrective Action To be taken	Projected Date of Completion	Estimated Cost Labor / Materials
<ol style="list-style-type: none"> 1. Signage / Parking Area / Modify door entrances. 2. Modify male urinals; install grab bars, and faucets levers. 3. Insufficient sheltered area for handicap access. 	<ol style="list-style-type: none"> 1. Establish and label proper parking areas to accommodate handicap motorist. <ol style="list-style-type: none"> 1.1 Install ramp to building entrance 2. Lower urinals, stall to accommodate wheelchairs and install proper faucets and grab bars to meet ADA standards. 3. Construct covered sheltered area for wheelchair access 	<ol style="list-style-type: none"> 1. - 3. To be Determined 	

Comments:

ALABAMA DEPARTMENT OF TRANSPORTATION

Americans with Disabilities Act
Self-Evaluation Cost Form

Date: October 2010

District 3 / Evergreen
Rest Area

Division: Ninth

District/Location:

Problem Identified	Corrective Action To be taken	Projected Date of Completion	Estimated Cost Labor / Materials
<p>1. Signage / Parking Area / Modify door entrances.</p> <p>2. Insufficient sheltered area for handicap access.</p>	<p>1. Establish and label proper parking areas to accommodate handicap motorist.</p> <p>1.2 Place proper signs to direct handicap motorist to designated areas.</p> <p>2.0 Construct covered sheltered area for wheelchair access.</p>	<p>1. - 2. To be Determined</p>	

Comments:

STIP

ALABAMA DEPARTMENT OF TRANSPORTATION
STATEWIDE TRANSPORTATION IMPROVEMENT PROGRAM
AMENDMENT # 9

DIV	PJ_REF_ID	SCOPE	COUNTY	DESCRIPTION	FEDERAL	STATE	OTHER	IN KIND	TOTAL	DATE
00	100051770	CN	STATEWIDE	STATEWIDE LEVEL OF EFFORT FOR ADA IMPROVEMENTS TO DIVISION AND DISTRICT OFFICES FY 2008	\$0.00	\$323,687.00	\$0.00	\$0.00	\$323,687.00	5/15/2008
			STATE-FUNDS-2008()	UNCLASSIFIED					LENGTH 0	
00	100051773	CN	STATEWIDE	STATEWIDE LEVEL OF EFFORT FOR ADA IMPROVEMENTS TO REST AREAS AND WELCOME CENTERS FY 2008	\$134,232.00	\$33,558.00	\$0.00	\$0.00	\$167,790.00	5/15/2008
			STPAA-2008()	UNCLASSIFIED					LENGTH 0	
00	100051771	CN	STATEWIDE	STATEWIDE LEVEL OF EFFORT FOR ADA IMPROVEMENTS TO DIVISION AND DISTRICT OFFICES FY 2009	\$0.00	\$206,657.00	\$0.00	\$0.00	\$206,657.00	10/15/2008
			STATE-FUNDS-2009()	UNCLASSIFIED					LENGTH 0	
00	100051774	CN	STATEWIDE	STATEWIDE LEVEL OF EFFORT FOR ADA IMPROVEMENTS TO REST AREAS AND WELCOME CENTERS FY 2009	\$76,016.00	\$19,004.00	\$0.00	\$0.00	\$95,020.00	10/15/2008
			STPAA-2009()	UNCLASSIFIED					LENGTH 0	
00	100051772	CN	STATEWIDE	STATEWIDE LEVEL OF EFFORT FOR ADA IMPROVEMENTS TO DIVISION AND DISTRICT OFFICES FY 2010	\$0.00	\$567,000.00	\$0.00	\$0.00	\$567,000.00	10/15/2009
			STATE-FUNDS-2010()	UNCLASSIFIED					LENGTH 0	
00	100051775	CN	STATEWIDE	STATEWIDE LEVEL OF EFFORT FOR ADA IMPROVEMENTS TO REST AREAS AND WELCOME CENTERS FY 2010	\$92,000.00	\$23,000.00	\$0.00	\$0.00	\$115,000.00	10/15/2009
			STPAA-2010()	UNCLASSIFIED					LENGTH 0	
04	100051782	RW	CALHOUN	REPL BRIDGES SR-74 (US-278) OVER NANCES CK (BIN 001272), OVER LADIGA CK (BIN 001273), OVER TERRAPIN CK RELIEF (BIN 001274), OVER TERRAPIN CK (BIN 001275), OVER TERRAPIN CK RELIEF (BIN 001276) AND OVER TERRAPIN CK RELIEF (BIN 001277). BRIDGE REPLACEMENT	\$36,000.00	\$9,000.00	\$0.00	\$0.00	\$45,000.00	6/1/2008
			BRF-0074()						LENGTH 0.44	

FUNCTIONAL CLASS: RURAL-PRINCIPAL ARTERIAL